



Contents lists available at ScienceDirect

Engineering

journal homepage: www.elsevier.com/locate/eng

Research
Smart Grid and Energy Internet—Article

Jaya Learning-Based Optimization for Optimal Sizing of Stand-Alone Photovoltaic, Wind Turbine, and Battery Systems

Asif Khan, Nadeem Javaid*

COMSATS University Islamabad, Islamabad 44000, Pakistan

ARTICLE INFO

Article history:

Received 3 November 2018

Revised 26 March 2020

Accepted 12 June 2020

Keywords:

Unit sizing

Stand-alone system

Renewable energy sources

Energy storage system

Optimization

Loss of power supply probability

ABSTRACT

Renewable energy sources (RESs) are considered to be reliable and green electric power generation sources. Photovoltaics (PVs) and wind turbines (WTs) are used to provide electricity in remote areas. Optimal sizing of hybrid RESs is a vital challenge in a stand-alone environment. The meta-heuristic algorithms proposed in the past are dependent on algorithm-specific parameters for achieving an optimal solution. This paper proposes a hybrid algorithm of Jaya and a teaching-learning-based optimization (TLBO) named the JLBO algorithm for the optimal unit sizing of a PV-WT-battery hybrid system to satisfy the consumer's load at minimal total annual cost (TAC). The reliability of the system is considered by a maximum allowable loss of power supply probability (LPSP_{max}) concept. The results obtained from the JLBO algorithm are compared with the original Jaya, TLBO, and genetic algorithms. The JLBO results show superior performance in terms of TAC, and the PV-WT-battery hybrid system is found to be the most economical scenario. This system provides a cost-effective solution for all proposed LPSP_{max} values as compared with PV-battery and WT-battery systems.

© 2020 THE AUTHORS. Published by Elsevier LTD on behalf of Chinese Academy of Engineering and Higher Education Press Limited Company. This is an open access article under the CC BY-NC-ND license (<http://creativecommons.org/licenses/by-nc-nd/4.0/>).

1. Introduction

Traditional energy generation uses fossil-fuel resources such as oil, natural gas, and coal, which are depleted with consumption [1] and cause environmental pollution and global warming. For example, the use and combustion of fossil fuels cause toxic air emissions that result in environmental problems with great risk to living organisms [2]. Carbon dioxide (CO₂) accounts for an estimated 77% of human-generated greenhouse gas emissions [3]. These factors contribute to toxic air emissions in the environment by harming the climate. Therefore, it is currently of the utmost importance to exploit new ways of producing energy that is more environmentally friendly, economical, clean, and inexhaustible by nature. Renewable energy sources (RESs) are an emerging trend and are widely used to generate power from various sources, including solar, wind, geothermal, hydropower, and other naturally replenishing energy sources [4]. Among RESs, wind turbines (WTs) and photovoltaics (PV) are the most dominant and encouraging technologies, and are considered by the global community to fulfill the load requirements of electricity consumers [5].

RESs that consist of solar and wind systems have come under more focus than other energy sources because they tend to reduce ecological and universal CO₂ emissions [6,7]. However, such resources can be unpredictable and intermittent, depending on natural conditions. The reliability of RESs is thus a major concern that needs to be tackled at a minimum cost to consumers. To overcome environmental challenges, there is a great need to consider RESs in energy production. RESs can be implemented in two ways: grid-connected (GC) and stand-alone (SA) modes. In GC modes, RESs inject the produced electricity to a power utility network, while in SA modes, they directly power up the consumer's electrical load [8].

In a GC system, the consumers are directly connected to the utility grid. In case of any shortfall of electricity from the RESs, consumers can obtain and fulfill their load requirements from the utility grid. Thus, there are no reliability concerns in the GC system. An SA system introduces unreliability concerns because consumers are only dependent on the power produced by the RESs, and there is no connectivity to a grid system. Furthermore, using a single RES in an SA environment results in high energy variations. This effect results in an energy mismatch situation, where the consumer's load requirements are not fulfilled by the generation capacity. To overcome RES unreliability and related challenges, Ref. [9] utilizes

* Corresponding author.

E-mail address: nadeemjavaidqau@gmail.com (N. Javaid).

<https://doi.org/10.1016/j.eng.2020.06.004>

2095-8099/© 2020 THE AUTHORS. Published by Elsevier LTD on behalf of Chinese Academy of Engineering and Higher Education Press Limited Company. This is an open access article under the CC BY-NC-ND license (<http://creativecommons.org/licenses/by-nc-nd/4.0/>).

Please cite this article as: A. Khan and N. Javaid, Jaya Learning-Based Optimization for Optimal Sizing of Stand-Alone Photovoltaic, Wind Turbine, and Battery Systems, Engineering, <https://doi.org/10.1016/j.eng.2020.06.004>

Nomenclature

A^{PV}	area of the PV panel	T_{factor}	teaching factor
CRF	capital recovery factor	T_{noct}	normal operating cell temperature
DoD	depth of discharge of battery	T^{ref}	PV cell temperature at reference conditions
$f(o)$	objective function in the Jaya algorithm	T^{rsc}	difference between the maximum and the minimum points in the temp curve
$f(o)_{best}$	foremost value of $f(o)$ in the entire solution	v	speed of the wind
$f(o)_{worst}$	worst value of $f(o)$ in the entire solution	v^i	cut-in wind speed
g	number of appliances	v^o	cut-out wind speed
i^r	interest rate	v^f	rated wind speed
I	solar radiation	X	total population size
I^{ref}	solar radiation under reference conditions	X_m^i	learner m in population X
LOPS	loss of power supply	X_n^i	learner n in population X
LPSP	loss of power supply probability	X_{new}	new population
$LPSP^{max}$	maximum allowable loss of power supply probability	$X_{teacher}$	teacher in TLBO algorithm
max(temp)	maximum generation point on the temp curve	ζ^b	unit cost of battery
min(temp)	minimum generation point on the temp curve	ζ_p^b	present worth of battery
n	life span of the system in years	ζ^{cap}	annual capital cost
N^b	number of batteries needed for battery bank	$\zeta^{inv/conv}$	unit cost of inverter/converter
$N^{b,max}$	maximum number of batteries	$\zeta_p^{inv/conv}$	present components worth of inverter/converter
$N^{inv/conv}$	number of the inverters/converters	ζ^{mtn}	annual maintenance cost
N^{pv}	number of PV panels	ζ^{pv}	unit cost of PV panel
$N^{pv,max}$	maximum number of PV panels	$\zeta^{pv,m}$	annual maintenance cost of the PV panels
N^{wt}	number of WTs	ζ^{tac}	total annual cost
$N^{wt,max}$	maximum number of WTs	ζ^{wt}	unit cost of WT
$O_{j,best,i}$	Jaya best candidate values of variable j for at i th iteration	$\zeta^{wt,m}$	annual maintenance cost of WTs
$O_{j,k,i}$	Jaya value of j th variable for the k th candidate during the i th iteration	η^b	battery bank charging efficiency
$O_{j,worst,i}$	Jaya worst candidate values of variable j for at i th iteration	η_i	efficiency of the inverter
p	appliances power ratings	η^{pv}	efficiency of the PV panel
P_r^{pv}	rated PV power	$\eta^{inv/conv}$	efficiency of the inverter/converter
P_r^{wt}	nominal power of WT	l	self-discharging state
$P_r^{inv/conv}$	rated power of inverter/converter	ζ^{gen}	accumulative power generation
POW^{pv}	PV panel power output	ζ^{ld}	consumer's load
POW^{wt}	WT power	ζ^{pv}	total produced PV power
r	random number	ζ^{store}	stored amount of energy in the battery bank
t	time slot	$\zeta^{store,max}$	battery bank maximum charge quantity
temp	temporary storage variable	$\zeta^{store,min}$	battery bank minimum charge quantity
T^{amb}	ambient air temperature	ζ^{wt}	total produced WT power
T^c	temperature of PV cell	ρ^b	battery price
T^{cof}	PV panels temperature coefficient	$\rho^{inv/conv}$	inverter/converter price
		χ	Boolean integer

a hybrid renewable energy system (HRES) along with an energy storage system (ESS) to fulfill the consumer's load. The complementary features of solar and wind energies are combined in the HRES, along with ESS backup. An ESS, which consists of batteries, fuel cells (FCs), and other technologies, is utilized to satisfy the deficit energy during stress time—that is, when the energy produced by RESs is less than the required load. Therefore, the power solution provided by an HRES along with an ESS is considered to be more sustainable and reliable than a single RES [10].

The primary issue in an HRES is determining the optimum size of individual components, including WTs, PVs, and batteries. Optimal sizing is required for strategic decisions such as feasibility studies, initial capital investments, or cost estimations. The methodology used to determine accurate and appropriate sizing of HRES components by maintaining the system's reliability at minimal total annual cost (TAC) is called unit sizing [11]. The unreliability of RESs can be overcome by oversizing the system's components; however, doing so results in an increased system cost. On the other hand, undersizing the system's components can lead to a loss of supply (LOS) problem, in which the energy produced by the RESs is less than the consumer's load. Therefore, optimum unit siz-

ing of an HRES that measures the exact number of a system's components at a reduced TAC is essential [12]. (Nomenclature is provided at the end of this paper.)

Software-based tools, formal techniques, and meta-heuristic algorithms are commonly used for the unit sizing of RESs. The hybrid optimization model for electric renewables (HOMER) is a software-based tool that is applied for energy optimization, sensitivity analysis, and planning. Mamaghani et al. [13] suggest the use of a PV-WT-diesel generator HRES for electrifying three remote off-grid villages in Colombia. A techno-economic feasibility analysis of the cost and an environmental evaluation in terms of CO₂ is conducted. The HOMER software tool is used for the techno-economical HRES analysis in order to fulfill 13 048 kW of average load requirements per day, with an estimated peak of 1185 kW [14]. The PV-WT-diesel-battery system provides optimal results of 17.15 million USD and 2 571 131 kg per year in terms of net present cost (NPC) and CO₂ emissions, respectively. In contrast, the electricity produced by a single diesel generator results in an NPC of 21.09 million USD and 5 432 244 kg per year of CO₂ emissions. Karmaker et al. [15] conduct an environmental and economic feasibility assessment of the use of a PV-biomass-battery

system to supply power to electric vehicles in Bangladesh. Results are obtained by means of the HOMER Pro software, which shows a 34.68% deduction in CO₂ emissions with the use of the proposed system in contrast to grid-based electric vehicle charging, along with savings of 12–18 USD per month. The HOMER software used in Refs. [13–15] suffers from some limitations and is not capable of performing multi-objective optimization; it only supports a uni-objective function based on NPC minimization. In addition, HOMER does not support intra-hour basis variability, and requires a huge computational time for large design points.

Considering the limitations of the HOMER software, works like Refs. [16–18] solve the optimal unit sizing of RESs through mixed-integer linear programming (MILP). Ren et al. [16] consider a GC scenario in which residential energy demands are fulfilled through a PV–FC–battery system. The authors propose a multi-objective function to reduce both annual cost and CO₂ emissions. The authors formulate the problem via MILP and consider selling energy back to the grid. The results demonstrate that batteries contribute to economic benefit while PVs provide an environmentally friendly solution. However, the MILP is a formal technique that suffers from some limitations. The MILP technique performs a complete search of the solution space to find an exact solution. However, this technique is not suitable for stochastic environments and suffers from the curse of the dimensionality problem for large design points.

Other studies have suggested the use of meta-heuristic algorithms, including the artificial bee swarm optimization (ABSO) [19], genetic algorithm (GA) [20–22], harmony search (HS) [23,24], and particle swarm optimization (PSO) [25–27], among others, which are more successive and highly efficient [28] in comparison with other approaches. However, techniques such as the HS, PSO, GA, and ABSO require algorithmic-specific parameters in order to function. For example, the HS algorithm uses harmony memory, pitch adjustment, and the consideration rate with several improvisations, while the PSO requires cognitive and social parameters with inertia weight values. The GA needs a selection operator along with crossover and mutation probabilities. Similarly, the ABSO cannot be executed without initialization and adjustment of algorithmic-specific parameters including the number of employed, scout, and onlooker “bees” with a limit specifier. Algorithms such as GA and ant colony optimization also require performance tuning of algorithmic-specific parameters in order to achieve optimal results. If not tuned properly, algorithmic-specific parameters may result in locally optimal solutions or an increased computational time.

Meta-heuristic algorithms such as PSO, ABSO, and GA require not only algorithmic-specific parameters, but also performance tuning of their parameters in order to achieve an optimal solution. The performance of these algorithms is mainly dependent on the selection, calibration, and performance tuning of these parameters. A small change in any parameter may affect the overall performance of the algorithm and may result in increased computation time or being stuck in local optima. Therefore, algorithms have been proposed in the literature, including Jaya [29], teaching-learning-based optimization (TLBO) [30], and improved TLBO [31], which do not need any algorithmic-specific parameters. Furthermore, the functioning of these algorithms is only dependent on certain common controlling parameters such as number of generations and population size.

This paper solves the unit sizing problem of an HRES via the Jaya, TLBO, and their hybrid, JLBO, algorithms. We consider a hybrid PV–WT–battery system, which is more ecofriendly and cost-effective than other hybrid systems utilizing diesel generators. The contributions listed below are an extension of our previous work [32]:

- Various components of the PV–WT–battery system are formulated and elaborated using an informative HRES model.
- Motivated by non-algorithmic-specific approaches, Jaya and TLBO algorithms are proposed to find an optimal number of HRES and their components to reduce the user’s annual electricity cost in an SA environment.
- A hybrid approach, JLBO, is proposed by combining Jaya and the learning phase of the TLBO algorithm for optimized searching of the solution space.
- The reliability of the system is considered using the various maximum allowable loss of power supply probability (LPSP_{max}) values provided by the consumer.

The rest of the paper is organized as follows. Section 2 depicts the proposed system model, sizing formulation, and objective function based on some constraints. The methods are given in Section 3. Simulation results are presented and discussed in Section 4. A conclusion and future work are provided in Section 5.

2. System model and sizing formulation

This section comprises the system model and the formulation of RES and TAC modeling.

2.1. The proposed system model

Fig. 1 displays a typical system model for a PV–WT–battery HRES. The proposed system model consists of a single direct current (DC) bus architecture. The bus is connected to dual RESs, including PV panels and WTs. The intermittent nature of solar and wind systems can cause nonlinear and unpredictable output power from RESs. Thus, using a single RES in an SA mode would result in energy variations. Therefore, an HRES comprising solar and wind systems is used in conjunction with an ESS. The ESS is composed of batteries, which are kept in a battery bank. Conventionally, the ESS uses deep-cycle lead-acid batteries.

Three different modes—balance, surplus, and deficit—are defined for the power generation from the RESs. In balance mode, the total power generated from RESs, including WTs and PVs, is equal to the total consumer’s load. Thus, there are no surplus or deficit powers. In surplus mode, the total energy produced by the RESs is greater than the total consumer’s load; therefore, the ESS is utilized and the additional energy is stored in the batteries of the power bank. Here, the flow of power is from the RESs to both home and ESS. In the power deficit mode, the RESs produce less power than is required by the user. Thus, the ESS is utilized to fulfill the consumer’s load in power deficit time slots. Here, the flow of power is from both the RESs and the ESS to the consumer’s load.




Fig. 1. Proposed system model for an HRES. AC: alternating current; DC: direct current.

Thus, the ESS in conjunction with RESs adds a reliability factor and makes the hybrid model economical for the user.

2.2. Sizing formulation of the proposed model

This section presents the modeling of the RESs, ESS, and TAC.

(1) **Sizing formulation of the PV power system.** The hourly PV panel power output POW^{PV} for solar radiation I is given by Eq. (1) [19]:

$$POW^{PV}(t) = P_r^{PV} \times (I/I^{ref}) \times [1 + T^{cof} (T^c - T^{ref})] \quad (1)$$

where $POW^{PV}(t)$ is the total hourly PV panels' power (W) generated at time slot t , P_r^{PV} is the rated PV power, I represents the solar insolation data ($W \cdot m^{-2}$), I^{ref} denotes the solar insolation under the reference conditions with a value of $1000 W \cdot m^{-2}$, and T^{cof} is the temperature coefficient of the PV panels and is set as $-3.7 \times 10^{-3} \text{ } ^\circ C^{-1}$ for mono- and polycrystalline silicon [19]. T^{ref} represents the PV cell temperature under the given reference conditions, which is normally set as $25 \text{ } ^\circ C$, while T^c represents the cell temperature, which can be obtained by Eq. (2):

$$T^c = T^{amb} + \frac{T^{noct} - 20}{800} \times I \quad (2)$$

where T^{amb} depicts the ambient air temperature ($^\circ C$), and T^{noct} represents the normal operating cell temperature ($^\circ C$). T^{noct} is dependent upon the manufacturer's specifications for the PV module.

If there exist a number of PV panels N^{PV} , then the total generated power ξ^{PV} can be given as follows:

$$\xi^{PV}(t) = N^{PV} \times POW^{PV}(t) \quad (3)$$

(2) **Sizing formulation of the WT power system.** The mechanism of the WT generator that produces electrical power is entirely based upon the wind's kinetic energy. The WT may be composed of two or more blades that are mechanically coupled to a motor that generates power depending on the speed of the wind. To increase the WT efficiency, the turbine is mounted high on a tower. The WT power POW^{WT} at time slot t is calculated by the following equation [33]:

$$\begin{cases} POW^{WT}(t) = 0, & v(t) < v^{ci} \\ POW^{WT}(t) = x \cdot [v(t)^3 - y \cdot P_r^{WT}], & v^{ci} < v(t) < v^r \\ POW^{WT}(t) = P_r^{WT}, & v^r < v(t) < v^{co} \\ POW^{WT}(t) = 0, & v(t) > v^{co} \end{cases} \quad (4)$$

where v represents the speed of the wind; P_r^{WT} denotes the nominal power of WT; and v^r , v^{co} , and v^{ci} represent the rated, cut-out, and cut-in wind speed, respectively. The parameters x and y can be obtained by Eq. (5):

$$\begin{cases} x = P_r^{WT} / [(v^r)^3 - (v^{ci})^3] \\ y = (v^{ci})^3 / [(v^r)^3 - (v^{ci})^3] \end{cases} \quad (5)$$

If there are the number N^{WT} of WTs installed in an area, then the overall produced wind power $\xi^{WT}(t)$ is obtained by the following equation:

$$\xi^{WT}(t) = N^{WT} \times POW^{WT}(t) \quad (6)$$

(3) **Accumulative power generation by RESs and the consumer's load formulation.** The PV and WT accumulative electric generation $\xi^{gen}(t)$ can be expressed as follows:

$$\xi^{gen}(t) = \xi^{PV}(t) \times \eta_i + \xi^{WT}(t) \times \eta_i^2 \quad (7)$$

where η_i represents the efficiency of the inverter.

In homes, the consumer's load ξ^{ld} at time slot t depends upon the appliances' usage. Thus, the ξ^{ld} can be computed by Eq. (8):

$$\xi^{ld}(t) = \sum_{g=a}^z p_g(t) \times \chi(t) \quad (8)$$

where g and p denote the number of appliances and their power ratings, respectively. $\chi(t)$ represents a Boolean integer showing an appliance status. When $\chi(t) = 1$, the appliance status is considered to be ON at hour t ; otherwise, it is considered to be OFF.

(4) **Sizing formulation of the battery bank.** The energy storage capacity of the battery bank is changed due to the intermittent nature of solar irradiation and wind speed. When $\xi^{gen}(t)$ is greater than $\xi^{ld}(t)$, the battery bank is in a state of charge (SOC). Thus, the charging quantity of the battery bank at time slot t is obtained by Eq. (9) [19]:

$$\xi^{store}(t) = \xi^{store}(t-1) \times (1 - \iota) + \left[\xi^{gen}(t) - \frac{\xi^{ld}(t)}{\eta_i} \right] \times \eta^b, \forall \xi^{gen}(t) > \xi^{ld}(t) \quad (9)$$

where $\xi^{store}(t)$ and $\xi^{store}(t-1)$ show the stored amount of energy in the battery bank at time slots t and $(t-1)$, respectively; ι represents the self-discharging state; and η^b denotes the battery bank charging efficiency.

When $\xi^{gen}(t)$ is less than $\xi^{ld}(t)$ at time slot t , the stored energy in the battery bank is utilized to fulfill the consumer's load. Here, the state of the battery bank is changed to discharging. The battery bank discharging efficiency is assumed to be 1, and temperature effects are not considered for this study. Thus, the battery bank charging quantity at time slot t is given by the following formula:

$$\xi^{store}(t) = \xi^{store}(t-1) \times (1 - \iota) - \left[\frac{\xi^{ld}(t)}{\eta_i} - \xi^{gen}(t) \right] / \eta_i, \forall \xi^{gen}(t) < \xi^{ld}(t) \quad (10)$$

2.3. Calculation of batteries for the battery bank

An important decision variable in the PV-WT-battery HRES is the calculation of the total number of batteries (N^b) required for the battery bank. N^b depends upon the consumer's load requirement and the generation capacity of the RESs. To find N^b , a temporary storage variable (temp) is supposed and initialized as 0. When the power generation from the RESs is higher than the consumer's load at an instant of time slot t , the temp stores energy, as per Eq. (9). However, when the power generation produced by the RESs is smaller than the consumer's load at time slot t , the temp variable is updated using Eq. (10). Thus, finding the total number of batteries for a system is dependent upon the curve of the variable temp. Positive temp values indicate the generation availability of the RESs, while negative values show a generation deficiency in the respective time slots. The total required storage capacity (T^{rsc}) is the difference between the maximum point and the minimum point in the temp curve, which can be obtained by the following equation:

$$T^{rsc} = \max(\text{temp}) - \min(\text{temp}) \quad (11)$$

Here, $\max(\text{temp})$ and $\min(\text{temp})$ represent the maximum and minimum generation points on the temp curve, respectively. Thus, the calculation for the N^b required for a given system can be derived using the following equation [34]:

$$N^b = \left\lceil \frac{T^{rsc}}{1.35} \right\rceil \quad (12)$$

where 1.35 is the nominal capacity of a battery.

2.4. System reliability

Reliability is an essential factor that must be considered in the SA system. Therefore, in this paper, the concept of the loss of power supply probability (LPSP) is considered and implemented to obtain a reliable HRES. The LPSP is elucidated by a number in the range of 0 and 1. An LPSP of 0 indicates that the system is very reliable and the consumer's load will always be fulfilled. An LPSP equal to 1 indicates that the consumer's load is never fulfilled. The LPSP for one year ($T = 8760$ h) can be expressed as follows:

$$LPSP = \frac{\sum_{t=1}^{8760} LOPS(t)}{\sum_{t=1}^{8760} \zeta^{ld}(t)} \quad (13)$$

where LOPS stands for loss of power supply. LOPS occurs when the total energy generated ζ^{gen} by the HRES is less than the total consumer's load ζ^{ld} at any time slot. LOPS is defined in Eq. (14).

$$LOPS(t) = \zeta^{ld}(t) - \zeta^{gen}(t), \forall t \in T \quad (14)$$

A flowchart for calculating the hybrid system's reliability is presented in Fig. 2. The flowchart is presented for the population size $X = 50$.




Fig. 2. Flowchart for calculating the hybrid system's reliability.

2.5. TAC formulation and constraints

In this section, an objective function based on the TAC minimization is formulated, along with constraints.

(1) **Objective function.** The objective function is based on finding the optimum number of components required for the HRES to satisfy the consumer's load at minimum TAC, expressed as (ζ^{tac}). The TAC is derived using two different costs: the annual capital cost (ζ^{cap}) and the annual maintenance cost (ζ^{mntn}). The former cost occurs at the start of a project, while the latter cost takes place during the life of the project. Thus, minimization of ζ^{tac} is given by the following formula:

$$\text{Minimize } \zeta^{tac} = \zeta^{cap} + \zeta^{mntn} \quad (15)$$

The initial capital cost needs to be converted to the annual capital cost. To do so, the capital recovery factor (CRF) approach is used. The CRF is obtained by Eq. (16) [19]:

$$CRF = \frac{i^r (1 + i^r)^n}{(1 + i^r)^n - 1} \quad (16)$$

where i^r represents the rate of interest and n depicts the system's lifespan in years.

Several of the components used in a PV-WT-battery HRES are frequently replaced during the project's lifespan. For example, the life of the battery is estimated to be five years. Similar to the approach used in Ref. [19], the present worth factor via single payment can be derived using Eq. (17):

$$\zeta_p^b = \rho^b \times \left[1 + \frac{1}{(1 + i^r)^5} + \frac{1}{(1 + i^r)^{10}} + \frac{1}{(1 + i^r)^{15}} \right] \quad (17)$$

where ζ_p^b represents the battery's present worth and ρ^b depicts the price of the battery.

Similarly, the lifetime of an inverter/converter is estimated to be ten years. Therefore, the present worth factor via single payment can be defined using Eq. (18):

$$\zeta_p^{inv/conv} = \rho^{inv/conv} \times \left[1 + \frac{1}{(1 + i^r)^{10}} \right] \quad (18)$$

where $\zeta_p^{inv/conv}$ represents the present components' worth of the inverter/converter and $\rho^{inv/conv}$ depicts the price of the inverter/converter.

Thus, by breaking apart the PV-WT-battery HRES into the annual costs of the PV panels, WTs, battery, and inverter/converter, Eq. (19) is obtained:

$$\zeta^{cap} = CRF \times \left(N^{wt} \times \zeta^{wt} + N^{pv} \times \zeta^{pv} + N^b \times \zeta^b + N^{inv/conv} \times \zeta^{inv/conv} \right) \quad (19)$$

where ζ^{wt} denotes the WT's unit cost, ζ^{pv} represents the PV panel's unit cost, ζ^b is the unit cost of the battery, $\zeta^{inv/conv}$ represents the unit cost of the inverter/converter, and $N^{inv/conv}$ depicts the quantity of the inverters/converters.

In order to obtain the system's components' annual maintenance cost ζ^{mntn} , Eq. (20) is used:

$$\zeta^{mntn} = N^{pv} \times \zeta^{pv,m} + N^{wt} \times \zeta^{wt,m} \quad (20)$$

where $\zeta^{pv,m}$ and $\zeta^{wt,m}$ denote the annual maintenance costs of the PV panels and WTs, respectively. In this paper, the maintenance costs of the inverter/converter and battery units are not considered.

(2) **Constraints.** The battery bank charge quantity at any time $\zeta^{store}(t)$ is subject to the minimum and maximum storage capacity constraint given by the following formula:

$$\zeta^{\text{store,min}} \leq \zeta^{\text{store}}(t) \leq \zeta^{\text{store,max}} \quad (21)$$

where $\zeta^{\text{store,max}}$ represents the battery bank maximum charge quantity. The $\zeta^{\text{store,max}}$ takes the nominal capacity ζ^{store} value of the battery bank. $\zeta^{\text{store,min}}$ shows the battery bank minimum charge quantity, which is calculated by Eq. (22):

$$\zeta^{\text{store,min}} = (1 - \text{DoD}) \times \zeta^{\text{store}} \quad (22)$$

where DoD represents the maximum depth of discharge.

In order to have a reliable system, the LPSP constraint given in Eq. (23) is considered during the cost minimization optimization process:

$$\text{LPSP} \leq \text{LPSP}^{\text{max}}, \forall 0 \leq \text{LPSP}^{\text{max}} \leq 1 \quad (23)$$

where LPSP^{max} represents the maximum allowable LPSP value, which is specified by the electricity consumer.

In addition, the following constraints for the total number of PV panels, WTs, and batteries should also be satisfied:

$$0 \leq N^{\text{pv}} \leq N^{\text{pv,max}}, \forall N^{\text{pv,max}} \leq 300 \quad (24)$$

$$0 \leq N^{\text{wt}} \leq N^{\text{wt,max}}, \forall N^{\text{wt,max}} \leq 200 \quad (25)$$

$$0 \leq N^{\text{b}} \leq N^{\text{b,max}}, \forall N^{\text{b,max}} \leq 20\,000 \quad (26)$$

where $N^{\text{pv,max}}$, $N^{\text{wt,max}}$, and $N^{\text{b,max}}$ denote the maximum number of PV panels, WTs, and batteries, respectively. In this paper, the minimum and maximum bounds for the decision variables are set at 0–300 for PV panels, 0–200 for WTs, and 0–20 000 for batteries. The components and parameters required for the PV–WT–battery hybrid system are given in Table 1 [19]. Fig. 3 provides a schematic diagram of the HRES process based on inputs, processing, and output.

Table 1
Hybrid system components and parameters.

Components	Parameters	Value
PV panel	P_r^{pv}	120 W
	ζ^{pv}	614 USD
	$\zeta^{\text{pv,m}}$	0 USD
	A^{pv}	1.07 m ²
	η^{pv}	12%
	T^{noct}	33 °C
WT	P_r^{wt}	1 kW
	v^{ci}	2.5 m·s ⁻¹
	v^{f}	11 m·s ⁻¹
	v^{co}	13 m·s ⁻¹
	ζ^{wt}	3200 USD
	$\zeta^{\text{wt,m}}$	100 USD
Battery	Voltage	12 V
	Battery nominal capacity	1.3 kW·h
	Lifespan	5 years
	η^{b}	85%
	ρ^{b}	130 USD
	DoD	0.8
	l	0.0002
Inverter/converter	$P_r^{\text{inv/conv}}$	3 kW
	Lifespan	10 years
	$\eta^{\text{inv/conv}}$	95%
	$\rho^{\text{inv/conv}}$	2000 USD
Other parameters	i^{r}	5%
	n	20 years

A^{pv} : area of the PV panel; η^{pv} : efficiency of the PV panel; $P_r^{\text{inv/conv}}$: rated power of inverter/converter; $\eta^{\text{inv/conv}}$: efficiency of the inverter/converter.

3. Proposed methodology

Inspired by the use of non-algorithmic-specific techniques, the optimum unit sizing problem is solved using Jaya, TLBO, and hybrid JLBO algorithms; their results are also compared with those of a GA, which requires the algorithmic-specific parameters of crossover and mutation.

3.1. Jaya

The Jaya optimization algorithm considers only common control parameters, including population size and termination criteria, and does not require any algorithmic-specific parameters for its execution. In the Jaya algorithm, the objective function $f(o)$ is minimized at each iteration i , having the number “ c ” of decision variables ($j = 1, 2, \dots, c$), and the number “ e ” of candidate solutions for a population size ($k = 1, 2, 3, \dots, e$). The best candidate $f(o)_{\text{best}}$ is selected, which has the foremost value of $f(o)$ in the entire solution. Similarly, the worst value of $f(o)$ is denoted by $f(o)_{\text{worst}}$, which is assigned as the worst candidate in the entire population. If $O_{j,k,i}$ represents the value of the j th variable for the k th candidate during the i th iteration, then it is changed according to the criteria defined by the following equation [29]:

$$O'_{j,k,i} = \lfloor \text{floor}[O_{j,k,i} + \text{rand}_{1,j,i}(O_{j,\text{best},i} - O_{j,k,i}) - \text{rand}_{2,j,i}(O_{j,\text{worst},i} - O_{j,k,i})] \rfloor \quad (27)$$

where $O_{j,\text{best},i}$ and $O_{j,\text{worst},i}$ are the values of variable j for the best and the worst candidates at the i th iteration, respectively. $O'_{j,k,i}$ depicts the updated value of $O_{j,k,i}$, while $\text{rand}_{1,j,i}$ and $\text{rand}_{2,j,i}$ denote the two random numbers for the j th variable during the i th iteration in the range from 0 to 1. The expression “ $\text{rand}_{1,j,i}(O_{j,\text{best},i} - O_{j,k,i})$ ” depicts the inclination of the solution to move toward the best solution, while the expression “ $\text{rand}_{2,j,i}(O_{j,\text{worst},i} - O_{j,k,i})$ ” shows the tendency to avoid the worst solutions. $O'_{j,k,i}$ is only accepted when it achieves a better fitness value. During the optimization process, accepted solutions are utilized to update the population for the next generation. To avoid negative and decimal values, we used the absolute and floor functions of MATLAB, respectively, to obtain an integer value for the decision variables.

3.2. Teaching–learning-based optimization

In TLBO, the rows and columns of the population represent the learners and subjects, respectively. Each subject of the learner is related to the decision variable, whereas the total number of subjects of the learner corresponds to a solution. The TLBO process is divided into two different phases: the teacher phase and the learner phase. The former phase shows learning from the teacher and the latter phase is associated with learning via interaction among the learners [30].

In the teacher phase, the mean of the learners is calculated as subject wise. All the learners are evaluated through the fitness function, and the best learner with the minimum TAC will be chosen as a teacher X^1_{teacher} . The algorithm now tries to shift the learners’ mean toward the teacher. Thus, a new vector formed by the current and best mean vectors is added to the existing population, as shown in Eq. (28):

$$X^1_{\text{new}(t)} = X^1_{\text{old}(t)} + r \times [X^1_{\text{teacher}} - (T_{\text{factor}} \times M^l)] \quad (28)$$

where r represents a random number in the range of 0 and 1, and T_{factor} is the teaching factor (TF). The TF is selected as either 1 or 2. It should be mentioned that T_{factor} is not taken as an input parameter; rather, it is randomly decided with an equal probability by the




Fig. 3. Schematic diagram of the HRES process.

algorithm during the optimization process, as given in the following equation:

$$T_{\text{factor}} = \text{round}[1 + r \times (2 - 1)] \quad (29)$$

and the X_{new}^1 in Eq. (28) is only accepted if it provides a better fitness function value.

In the learner phase, each learner randomly interacts with other learners in order to share and increase their knowledge. The process starts by randomly selecting two learners: X_m^1 and X_n^1 , from the existing population, such that $m \neq n$. Based on the fitness values of the learners, the population is updated by the following equation:

$$X_{\text{new}(t)}^1 = \begin{cases} X_{\text{old}(t)}^1 + r \times (X_m^1 - X_n^1), & \text{if } X_m^1 \leq X_n^1 \\ X_{\text{old}(t)}^1 + r \times (X_n^1 - X_m^1), & \text{otherwise} \end{cases} \quad (30)$$

The optimization process of the algorithm continues until some termination criterion is met.

3.3. JLBO

JLBO is composed of Jaya followed by the learning phase of TLBO, which results in an increased search power around the global solution. Fig. 4 shows the flowchart of the optimization process of the JLBO algorithm. The mapping steps of the JLBO algorithm to obtain an optimum unit sizing solution for the HRES are given below.

Step 1: The hourly input parameters, including solar irradiation, wind speed, ambient temperature, and consumer's load profile data, are taken as input.

Step 2: Based on the input data, the power generation capacities of individual PV panels and WT's are calculated via Eqs. (1) and (4).

Step 3: An initial population with the size of 50 is randomly generated, consisting of only two decision variables: $\mathbf{X} = [N^{\text{pv}}, N^{\text{wt}}]$. In this position vector, the first element depicts the total number of PV panels and the second term represents the total number of WT's. To keep the decision variables within the search space, the minimum and maximum bounds (constraints) given in Eqs. (24) and (25) must be satisfied.

Step 4: Here, we calculate the number of batteries for each solution of \mathbf{X} using Eq. (12), and apply the constraint given in Eq. (26). \mathbf{X} is updated such that it now represents three integer decision parameter values: $\mathbf{X} = [N^{\text{pv}}, N^{\text{wt}}, N^{\text{b}}]$. Here, the third element corresponds to the total number of batteries. These performance parameters are the decision variables of the unit sizing problem. Thus, the initial population generated now consists of a matrix size of $[50 \times 3]$, where 50 represents the rows and 3 depicts the columns

for each performance parameter. Each corresponding row of population \mathbf{X} depicts a solution to the unit sizing problem.

Step 5: The LPSP of each solution of \mathbf{X} is found via Eq. (13). Now only those solutions are considered that satisfy the LPSP_{max} constraint given in Eq. (23).

Step 6: In this step, the cost values for each solution in \mathbf{X} are computed using Eq. (15). Depending on the values of the fitness function, the best and worst solutions in \mathbf{X} are now selected.

Step 7: Using Jaya Eq. (27), the first two elements (N^{pv} and N^{wt}) of the entire \mathbf{X} are updated.

Step 8: During the learner phase, two solutions— X_m and X_n —are randomly selected from \mathbf{X} . Based on the fitness function values, X_{new} is updated via Eq. (30). X_{new} now contains the updated population values.

Step 9: Finally, Steps 4–8 are repeated until a termination criterion (in this work, 100 generations) is met.

Step 10: The best solution among all generations based on the TAC is selected as an optimal solution, and the corresponding performance parameter values are returned.

3.4. Genetic algorithm

The GA is a bio-inspired algorithm that is dependent on the genetic evaluation and survival of the fittest concepts [35]. The GA has been widely applied to energy management via appliances scheduling [36,37] and unit sizing problems of hybrid systems [38]. In a GA, the algorithmic-specific parameters, including selection, mutation, and crossover operators, are initialized and tuned during the optimization process to achieve a near-optimal global solution. Like other meta-heuristic algorithms, the GA process starts by randomly generating an initial population (X) with N numbers and D dimensional space. The genes present in the D dimension space represent the decision variables of the problem. In a GA, a chromosome is a complete row consisting of several genes forming a candidate solution to the problem. As the GA optimization process evolves, all chromosomes are evaluated through a fitness function, which is TAC minimization in this study. During an iteration, the best chromosome represents the local best solution (L_{best}).

To produce a new population (X_{new}) for the next generation, mutation and crossover strategies are applied. The process repeats and X_{new} is evaluated through the fitness function. Newer solutions with better TAC are used to replace the previous ones until the termination criterion is satisfied. The best solution with the minimum TAC is selected among all generations as the globally best (G_{best}) solution. The crossover and mutation values for this study are set to 0.8 and 0.2, respectively.




Fig. 4. Flowchart of the JLBO algorithm.

4. Simulation results

The simulation results were obtained using MATLAB R2016a software with a system with a 2.9 GHz Intel Core i7 processor with 8 GB of installed memory. A dataset containing hourly data for solar insolation (Fig. 5), ambient temperature (Fig. 6), and wind speed at a height of 10 m (Fig. 7) was obtained for a year (8760 h) from Rafsanjan, Iran [39]. Figs. 5(a)–7(a) and Figs. 5(b)–7(b) depict the solar insolation, ambient temperature, and wind speed data during the year and during the first 8 d of the year (192 h), respectively. A consumer's load profile for a year and during the first 8 d is presented in Figs. 8(a) and (b), respectively. The initial charge of the batteries is assumed to be 30% of their nominal storage capacity.

Table 2 summarizes and elaborates the TAC results obtained by algorithms for the optimal sizing of an HRES. In this table, the mean values, standard deviation, and best and worst indexes of each algorithm for all hybrid cases are given. The indexes are reported over 10 independent runs. In Table 2, the average rank

values of the proposed algorithms are derived by taking the mean of their mean values calculated for all three cases: PV–WT–battery, PV–battery, and WT–battery. For example, the JLBO average rank value 85 183 USD is obtained by taking a mean of 50 247, 67 052, and 138 250 USD achieved by the PV–WT–battery, PV–battery, and WT–battery cases, respectively. The various ranks of the algorithms are assigned based on the average rank of the TACs. As shown in Table 2, the JLBO results show that at $LPS_{max} = 1\%$, the PV–WT–battery hybrid system is the most cost-effective solution with a TAC of 50 247 USD, compared with the WT–battery and PV–battery systems with TAC values of 138 250 and 67 052 USD, respectively. The best and worst indexes in Table 2 show the best and worst solutions found by the algorithms during 10 independent runs. The standard deviation is defined as a quantity expressing by how much the members of a group differ from the mean value for the group. In Table 2, for the PV–battery, WT–battery, and PV–WT–battery cases, JLBO achieved the same best and worst solutions in 10 independent runs; therefore, it resulted in a standard deviation value of 0.




Fig. 5. Hourly solar insolation profile data (a) during a year and (b) during the first 8 d of the year.




Fig. 6. Hourly ambient temperature profile data (a) during a year and (b) during the first 8 d of the year.




Fig. 7. Hourly wind speed profile data (a) during a year and (b) during the first 8 d of the year.




Fig. 8. Hourly consumer's load profile data (a) during a year and (b) during the first 8 d of the year.

Table 2
Summary of the mean, standard deviation (Std.), best performance, worst performance, and ranks of the schemes over 10 independent runs for the proposed hybrid systems at LPSP_{max} = 1%.

Hybrid systems	Index	Jaya	TLBO	JLBO	GA
PV-WT-battery	Mean (USD)	50 596	51 458	50 247	54 626
	Std. (USD)	173.1658	1 790.2	0	4 539.9
	Best (USD)	50 268	50 268	50 247	50 247
	Worst (USD)	50 678	55 621	50 247	63 565
PV-battery	Mean (USD)	67 052	67 052	67 052	67 052
	Std. (USD)	0	0	0	0
	Best (USD)	67 052	67 052	67 052	67 052
	Worst (USD)	67 052	67 052	67 052	67 052
WT-battery	Mean (USD)	138 250	138 250	138 250	138 250
	Std. (USD)	0	0	0	0
	Best (USD)	138 250	138 250	138 250	138 250
	Worst (USD)	138 250	138 250	138 250	138 250
Average rank (USD)		85 299.33	85 586.67	85 183	86 642.67
Final rank		2	3	1	4

In the case of the PV-WT-battery system listed in Table 2, the optimal sizing that was found for the best index by the Jaya algorithm is $N^{PV} = 160$, $N^{WT} = 9$, and $N^b = 1296$, with a TAC of 50 268 USD and an LPSP of 0.9650%. The worst solution found by the Jaya algorithm results in a TAC of 50 678 USD with optimal sizing of $N^{PV} = 155$, $N^{WT} = 10$, and $N^b = 1306$ and an LPSP of 0.9340%. The best solution found by the TLBO algorithm is the same as that obtained by Jaya. The worst solution found by the TLBO algorithm achieved optimal sizing of $N^{PV} = 144$, $N^{WT} = 13$, and $N^b = 1453$ with a TAC of 55 621 USD and an LPSP of 0.5859%. In the case of the hybrid JLBO, both the best and worst solutions were the same, with a TAC of 50 247 USD, optimal sizing of $N^{PV} = 165$, $N^{WT} = 8$, and $N^b = 1299$, and an LPSP of 0.9817%. The best index value obtained using the GA was the same as that obtained using the hybrid JLBO. The worst solution obtained by the GA resulted in a TAC of 63 565 USD with a unit sizing combination of $N^{PV} = 115$, $N^{WT} = 20$, and $N^b = 1682$ and an LPSP of 0.8211%.

For the PV-battery and WT-battery systems, all the algorithms achieved the same best and worst solutions, resulting in a standard deviation value of 0. In the case of the PV-battery system, the best and worst solutions resulted in the same TAC of 67 052 USD with optimal sizing values of $N^{PV} = 202$ and $N^b = 1893$ for PV panels and batteries, respectively, and an LPSP value of 0.9715%. In the WT-battery system, we found similar results for the best and worst cases for all algorithms, with a TAC of 138 250 USD and optimal sizing of $N^{WT} = 54$ and $N^b = 3954$. At LPSP_{max} = 1%, the LPSP obtained by all algorithms was 0.8744%. Therefore, it was revealed that all of the algorithms had a similar performance for the PV-battery and WT-battery systems due to the lower number of decision variables involved in the system, in comparison with the PV-WT-battery system. In the case of the PV-WT-battery system, as the number of decision variables was increased to three (i.e., N^{PV} , N^{WT} , and N^b), the performance of the algorithms varied. The comparative performances of the Jaya, TLBO, JLBO, and GA algorithms at LPSP_{max} = 1%, showed that the JLBO results were better in terms of mean, standard deviation, and best and worst indexes for the PV-WT-battery system. It is pertinent to note that all the proposed algorithms were evaluated over the same number of generations. The algorithms are therefore ranked as follows based on the fitness values they achieved for the TAC: JLBO, Jaya, TLBO, and GA.

For simplicity, only the results of the Jaya and JLBO algorithms for the proposed hybrid systems are summarized in Table 3. This table provides the optimum results for the decision variables N^{PV} , N^{WT} , and N^b in terms of the minimized TAC values at five different LPSP_{max} achieved by the aforementioned algorithms. It is notable that at all LPSP_{max} values, the PV-WT-battery system is economi-

cal in terms of TAC, in comparison with the PV-battery and WT-battery systems. Due to its enhanced search for more promising areas of the solution space, the hybrid JLBO achieved better results for the PV-WT-battery system. For the PV-battery and WT-battery systems, the results achieved by Jaya and TLBO were similar for all TACs at different LPSP_{max} values.

When considering the Jaya algorithm, it was found that at LPSP_{max} = 0, a TAC of 66 863 USD was achieved with 145 PV panels, 15 WTs, and 1802 batteries for the PV-WT-battery system. As the values of LPSP_{max} increased from 0 to 5%, the corresponding TAC values decreased due to the tradeoff effect between the cost and reliability of the system. In other words, the system is more reliable but costly and will always fulfill the consumer's load demand at LPSP_{max} = 0 as compared with other LPSP_{max} values, where LOS is probably caused by a lower amount of power generation from the RESs. At an increased value of LPSP_{max}, that is, at 5%, the PV-WT-battery system achieved the minimum TAC value of 35 555 USD for the Jaya algorithm. An analysis of Table 3 reveals that the PV-WT-battery system provides a more economical solution than the PV-battery and WT-battery systems for the Jaya algorithm. For example, when the LPSP_{max} value is set to 5%, TAC values of 35 555, 39 409, and 138 250 are achieved for the PV-WT-battery, PV-battery, and WT-battery systems, respectively.

Table 3 also reveals that more promising and efficient results are obtained concerning the minimized TAC values by the JLBO algorithm for the PV-WT-battery HRES as compared with the Jaya algorithm. At LPSP_{max} = 0, the TAC value achieved by the JLBO algorithm is 66 542 USD, which is 321 USD less than that of the Jaya scheme. Here, the optimum sizing found by the JLBO algorithm is $N^{PV} = 150$, $N^{WT} = 14$, and $N^b = 1795$. When the LPSP_{max} value is set at 0.3%, the TAC achieved by the JLBO algorithm is 60 752 USD, which is 350 USD less than that obtained by Jaya. In this case, the optimum size of the components is $N^{PV} = 144$, $N^{WT} = 14$, and $N^b = 1612$, with an obtained LPSP value of 0.2962%. At LPSP_{max} = 1%, the PV-WT-battery system, with a TAC value of 50 247 USD and optimum sizing of $N^{PV} = 165$, $N^{WT} = 8$, and $N^b = 1299$, is found to be the most cost-effective HRES in comparison with the PV-battery and WT-battery systems. Here, the total cost saved by JLBO is 21 USD in comparison with the Jaya algorithm. Furthermore, when LPSP_{max} is increased to 2%, the optimum sizing obtained by the JLBO is $N^{PV} = 168$, $N^{WT} = 6$, and $N^b = 1078$ with a TAC and an LPSP of 43 046 USD and 1.7976%, respectively. In this case, the cost saved by JLBO is 20 USD in comparison with the Jaya scheme. Finally, at LPSP_{max} = 5%, the TAC value found by JLBO is 34 464 USD for the PV-WT-battery system, which is 1091 USD less than the solution obtained by the Jaya scheme. In this case, the opti-

Table 3
Summary of Jaya and JLBO results for the proposed hybrid systems at different LPSP_{max} values.

Hybrid systems	LPSP _{max} (%)	Jaya					JLBO				
		LPSP (%)	N ^{PV}	N ^{WT}	N ^b	TAC (USD)	LPSP (%)	N ^{PV}	N ^{WT}	N ^b	TAC (USD)
PV-WT-battery	0	0	145	15	1802	66 863	0	150	14	1 795	66 542
	0.3	0.2721	139	15	1 620	61 102	0.2962	144	14	1 612	60 752
	1.0	0.9650	160	9	1 296	50 268	0.9817	165	8	1 299	50 247
	2.0	1.8080	172	5	1 084	43 066	1.7976	168	6	1 078	43 046
	5.0	4.6908	170	4	849	35 555	4.8372	174	3	818	34 464
PV-battery	0	0	213	N/A	2 601	88 853	0	213	N/A	2 601	88 853
	0.3	0.2097	210	N/A	2 404	82 790	0.2097	210	N/A	2 404	82 790
	1.0	0.9715	202	N/A	1 893	76 052	0.9715	202	N/A	1 893	76 052
	2.0	1.9158	193	N/A	1 354	50 424	1.9158	193	N/A	1 354	50 424
	5.0	4.5991	187	N/A	997	39 409	4.5991	187	N/A	997	39 409
WT-battery	0	0	N/A	56	4 246	147 730	0	N/A	56	4 246	147 730
	0.3	0	N/A	55	4 072	142 150	0	N/A	55	4 072	142 150
	1.0	0.8744	N/A	54	3 954	138 250	0.8744	N/A	54	3 954	138 250
	2.0	0.8744	N/A	54	3 954	138 250	0.8744	N/A	54	3 954	138 250
	5.0	0.8744	N/A	54	3 954	138 250	0.8744	N/A	54	3 954	138 250

N/A: not applicable.

imum sizing of the system components is N^{PV} = 174, N^{WT} = 3, and N^b = 818, with an LPSP value of 4.8372%.

As shown in Table 3, the results obtained by the JLBO algorithm for the PV-battery system are more economical in terms of TAC than those for the WT-battery system. The TAC values obtained for the PV-battery system at LPSP_{max} = 0, 0.3%, 1%, 2%, and 5% are 88 853, 82 790, 76 052, 50 424, and 39 409 USD, respectively. In the case of the WT-battery system, the TAC values obtained are 147 730, 142 150, and 138 250 at LPSP_{max} = 0, 0.3%, 1%, 2%, and 5%, respectively. The simulation plots obtained by the JLBO algorithm for performance parameters including RESs power generation, status of energy storage in the battery bank, and TAC values along with their convergence are discussed next.

The fulfillment of the consumer's load at any time instant is mainly dependent on the RES power generation and the extent of energy stored in the battery bank. Figs. 9 and 10 present the hourly produced power by the PV panels and WTs, along with the expected amount of stored energy in the battery bank throughout a year and during the first 8 d of the year, respectively, for the PV-WT-battery HRES considering various LPSP_{max} values. As depicted in Fig. 9(a), the maximum PV power is produced at LPSP_{max} values of 5% and 2%, with N^{PV} of 174 and 168, respectively. The least amount of power produced by PV panels is at LPSP_{max} = 0.3%, with N^{PV} = 144. In Fig. 9(b), the highest produced power by WTs has a similar profile for LPSP_{max} values of 0 and 0.3% because of the equal number of N^{WT}, that is, 14. The lowest power is produced when the installed number of WTs is 3 at LPSP_{max} = 5% for the PV-WT-battery hybrid system.

The expected amount of energy stored in the battery bank during a year and the first 8 d of the year is plotted in Figs. 9(c) and 10 (c), respectively, at five different LPSP_{max} values. It is found that a large amount of energy is stored at LPSP_{max} = 0 because of the large number of installed batteries (N^b = 1795). In this case, the consumer must bear the maximum TAC value of 66 542 USD. As shown in Fig. 9(c), an increase in LPSP_{max} value results in a decreased amount of stored energy in the battery bank due to the lower number of batteries. For example, at LPSP_{max} = 0.3%, 1%, 2%, and 5%, the number of batteries N^b is 1612, 1299, 1078, and 818, respectively. Furthermore, loss of load (LOL) is caused at time slots when the amount of stored energy in the batteries reaches the minimum allowable limit.

The hourly produced PV power and energy storage level of the PV-batteries system throughout a year and during the first 8 d of the year at different LPSP_{max} values are presented in Figs. 11 and 12, respectively. As shown in Fig. 11(a), at LPSP_{max} = 0, the hourly




Fig. 9. Hourly produced power and energy storage level of the PV-WT-battery system achieved by the JLBO algorithm during a year at different LPSP_{max} values. (a) Produced PV power; (b) produced WT power; (c) battery energy storage level.




Fig. 10. Hourly produced power and energy storage level of the PV-WT-battery system achieved by the JLBO algorithm during the first 8 d of the year at different LPSP_{max} values. (a) Produced PV power; (b) produced WT power; (c) battery energy storage level.

produced power is the highest, with 213 PV panels. Accordingly, the consumer bears a maximum TAC of 88 853 USD. When the LPSP_{max} value increases, there is a relative decrease in the hourly produced PV power, along with the TAC values. At LPSP_{max} values of 0.3%, 1%, 2%, and 5%, the number of PV panels obtained by JLBO decreases to 210, 202, 193, and 187, respectively. Based on this fact, the amount of power generated by the PV panels is also reduced. The corresponding PV power for the first 8 d of the year is given in Fig. 12(a). Thus, depending on the solar insolation and ambient temperature data profiles, the daily output power of the PV panels varies accordingly.

Fig. 11(b) presents the hourly battery energy storage level of the PV-battery system. As has been already mentioned, it is assumed that the batteries are initially 30% charged. Thus, for different LPSP_{max}, the starting storage points are dependent upon the number of batteries. For example, at LPSP_{max} = 0, the PV-battery system results in the highest amount of storage capacity with N^{PV} = 213 and a TAC value of 88 853 USD. Similarly, a decrease in the




Fig. 11. Hourly produced power and energy storage level of the PV-battery system achieved by the JLBO algorithm during a year at different LPSP_{max} values. (a) Produced PV power; (b) battery energy storage level.




Fig. 12. Hourly produced power and energy storage level of the PV-battery system achieved by the JLBO algorithm during first 8 d of the year at different LPSP_{max} values. (a) Produced PV power; (b) battery energy storage level.




Fig. 13. Hourly produced power and energy storage level of the WT-battery system by the JLBO algorithm during a year at different $LPSP_{max}$ values. (a) Produced WT power; (b) battery energy storage level.

expected mass of stored energy is evident with increasing $LPSP_{max}$ values due to the tradeoff effect between the system's reliability




Fig. 14. Hourly produced power and energy storage level of the WT-battery system achieved by the JLBO algorithm during the first 8 d of the year at different $LPSP_{max}$ values. (a) Produced WT power; (b) battery energy storage level.




Fig. 15. Convergence process of the JLBO algorithm for obtaining optimum results at different $LPSP_{max}$ values. (a) PV-WT-battery system; (b) PV-battery system; (c) WT-battery system.

and the TAC. The stored mass of energy is the lowest at an $LPSP_{max}$ of 5%, with a TAC value of 39 409 USD. The corresponding energy storage level plot during the first 8 d of the year at different $LPSP_{max}$ is given in Fig. 12(b). Since the PV-battery system initially utilizes the amount of stored energy in the battery bank due to the lack of renewable power from PV panels, a declining trend in energy storage is observed in Fig. 12(b).

Figs. 13 and 14 illustrate the hourly produced power and energy storage levels of the WT-battery system for a year and during the first 8 d of the year, respectively, at different $LPSP_{max}$ values. The highest power is produced by WTs at $LPSP_{max} = 0$, with the maximum number of WTs installed—that is, 56. When $LPSP_{max}$ is increased to 0.3%, N^{WT} decreases to 55, resulting in reduced power in comparison with $LPSP_{max} = 0$. The power produced by the WT-battery system during the first 8 d of the year at different $LPSP_{max}$ is given in Fig. 14(a). The profiles depicting the WT-produced power in Fig. 13(a) and the stored amount of battery energy in Fig. 13(b) at $LPSP_{max}$ values of 1%, 2%, and 5% are similar to those of the same number of batteries and WTs ($N^b = 3954, N^{WT} = 54$). Due to this fact, for the aforementioned three $LPSP_{max}$ values, the TAC borne by the

consumer is the same, at 138 250 USD. Similar behavior is observed in the hourly produced WT power and energy storage level of the WT–battery system during the first 8 d of the year in Figs. 14(a) and (b), respectively.

Fig. 15 represents the convergence process of the JLBO algorithm while minimizing the TAC of the proposed HRES. It is notable that, at each iteration, the JLBO scheme decreases the TAC value based on the fitness function. This confirms the performance and efficiency of the proposed JLBO scheme for the optimal unit sizing problem. It is also observed that the convergence process of the JLBO algorithm for the PV–battery and WT–battery systems as given in Figs. 15(b) and (c), respectively, is relatively faster than that for the PV–WT–battery system shown in Fig. 15(a), due to the presence of fewer decision variables.

To summarize, it can be stated that the proposed hybrid algorithm JLBO has more promising and cost-effective results than the other algorithms. Furthermore, non-algorithmic-specific parameter schemes, including Jaya and TLBO, are simple because no performance tuning and calibration of their parameters is needed.

5. Conclusion and future work

In this paper, non-algorithmic-specific parameter schemes were proposed in order to find and evaluate the optimum size of the HRES components required to fulfill the consumer's load at minimum TAC. To achieve this goal, all components required for the HRES were modeled and a fitness function based on TAC minimization was formulated. The system's reliability was ensured using various LPSP_{max} values. To find the optimum unit size of the hybrid system components, Jaya, TLBO, hybrid JLBO, and GA algorithms were applied. When considering the optimization aspect, it was found that the hybrid JLBO algorithm yields more promising and economical results than its ancestors or the GA in terms of the TAC. The PV–WT–battery hybrid system was found to have the most cost-effective solution, with TAC values of 66 542, 60 752, 50 247, 43 046, and 34 464 USD at LPSP_{max} values of 0, 0.3%, 1%, 2%, and 5%, respectively. The PV–battery system is the second-most economical solution, and the WT–battery system comes last.

In the future, we are interested in extending this work by comparing it with different meta-heuristic algorithms—including PSO, enhanced differential evaluation, artificial flora, and so forth—that require algorithmic-specific parameters.

6. Compliance with ethics guidelines

Asif Khan and Nadeem Javaid declare that they have no conflict of interest or financial conflicts to disclose.


Appendix A. Supplementary data

Supplementary data to this article can be found online at <https://doi.org/10.1016/j.eng.2020.06.004>.

References

- [1] Hosseini SE, Wahid MA. Feasibility study of biogas production and utilization as a source of renewable energy in Malaysia. *Renewable Sustainable Energy Rev* 2013;19:454–62.
- [2] Perera FP. Multiple threats to child health from fossil fuel combustion: impacts of air pollution and climate change. *Environ Health Perspect* 2017;125(2):141–8.
- [3] Rahman FA, Aziz MMA, Saidur R, Bakar WAWA, Hainin MR, Putrajaya R, et al. Pollution to solution: capture and sequestration of carbon dioxide (CO₂) and its utilization as a renewable energy source for a sustainable future. *Renewable Sustainable Energy Rev* 2017;71:112–26.
- [4] Ellabban O, Abu-Rub H, Blaabjerg F. Renewable energy resources: current status, future prospects and their enabling technology. *Renewable Sustainable Energy Rev* 2014;39:748–64.
- [5] Sawle Y, Gupta SC, Bohre AK. Review of hybrid renewable energy systems with comparative analysis of off-grid hybrid system. *Renewable Sustainable Energy Rev* 2018;81(Pt 2):2217–35.
- [6] Kabir E, Kumar P, Kumar S, Adelodun AA, Kim KH. Solar energy: potential and future prospects. *Renewable Sustainable Energy Rev* 2018;82(Pt 1):894–900.
- [7] Wagh S, Walke PV. Review on wind–solar hybrid power system. *Int J Res Sci Eng* 2017;3(2):71–6.
- [8] Bajpai P, Dash V. Hybrid renewable energy systems for power generation in stand-alone applications: a review. *Renewable Sustainable Energy Rev* 2012;16(5):2926–39.
- [9] Zhao H, Wu Q, Hu S, Xu H, Rasmussen CN. Review of energy storage system for wind power integration support. *Appl Energy* 2015;137:545–53.
- [10] Erdinc O, Uzunoglu M. Optimum design of hybrid renewable energy systems: overview of different approaches. *Renewable Sustainable Energy Rev* 2012;16(3):1412–25.
- [11] Luna-Rubio R, Trejo-Perea M, Vargas-Vázquez D, Ríos-Moreno GJ. Optimal sizing of renewable hybrids energy systems: a review of methodologies. *Sol Energy* 2012;86(4):1077–88.
- [12] Al Busaidi AS, Kazem HA, Al-Badi AH, Khan MF. A review of optimum sizing of hybrid PV–wind renewable energy systems in Oman. *Renewable Sustainable Energy Rev* 2016;53:185–93.
- [13] Mamaghani AH, Escandon SAA, Najafi B, Shirazi A, Rinaldi F. Techno-economic feasibility of photovoltaic, wind, diesel and hybrid electrification systems for off-grid rural electrification in Colombia. *Renew Energy* 2016;97:293–305.
- [14] Hossain M, Mekhilef S, Olatomiwa L. Performance evaluation of a stand-alone PV–wind–diesel–battery hybrid system feasible for a large resort center in South China Sea. *Sustain Cities Soc* 2017;28:358–66.
- [15] Karmaker AK, Ahmed MR, Hossain MA, Sikder MM. Feasibility assessment & design of hybrid renewable energy based electric vehicle charging station in Bangladesh. *Sustain Cities Soc* 2018;39:189–202.
- [16] Ren H, Wu Q, Gao W, Zhou W. Optimal operation of a grid-connected hybrid PV/fuel cell/battery energy system for residential applications. *Energy* 2016;113:702–12.
- [17] Okoye CO, Solyali O. Optimal sizing of stand-alone photovoltaic systems in residential buildings. *Energy* 2017;126:573–84.
- [18] Habib AH, Disfani VR, Kleissl J, de Callafon RA. Optimal switchable load sizing and scheduling for standalone renewable energy systems. *Sol Energy* 2017;144:707–20.
- [19] Maleki A, Pourfayaz F. Optimal sizing of autonomous hybrid photovoltaic/wind/battery power system with LPSP technology by using evolutionary algorithms. *Sol Energy* 2015;115:471–83.
- [20] Gan LK, Shek JKH, Mueller MA. Optimised operation of an off-grid hybrid wind–diesel–battery system using genetic algorithm. *Energy Convers Manage* 2016;126:446–62.
- [21] Ogunjuyigbe ASO, Ayodele TR, Akinola OA. Optimal allocation and sizing of PV/wind/split-diesel/battery hybrid energy system for minimizing life cycle cost, carbon emission and dump energy of remote residential building. *Appl Energy* 2016;171:153–71.
- [22] Maleki A, Khajeh MG, Rosen MA. Two heuristic approaches for the optimization of grid-connected hybrid solar–hydrogen systems to supply residential thermal and electrical loads. *Sustain Cities Soc* 2017;34:278–92.
- [23] Heydari A, Askarzadeh A. Optimization of a biomass-based photovoltaic power plant for an off-grid application subject to loss of power supply probability concept. *Appl Energy* 2016;165:601–11.
- [24] Eteiba MB, Barakat S, Samy MM, Wahba WI. Optimization of an off-grid PV/biomass hybrid system with different battery technologies. *Sustain Cities Soc* 2018;40:713–27.
- [25] Fathy A. A reliable methodology based on mine blast optimization algorithm for optimal sizing of hybrid PV–wind–FC system for remote area in Egypt. *Renew Energy* 2016;95:367–80.
- [26] Yilmaz S, Dincer F. Optimal design of hybrid PV–diesel–battery systems for isolated lands: a case study for Kilis, Turkey. *Renewable Sustainable Energy Rev* 2017;77:344–52.
- [27] Yahiaoui A, Benmansour K, Tadjine M. Control, analysis and optimization of hybrid PV–diesel–battery systems for isolated rural city in Algeria. *Sol Energy* 2016;137:1–10.
- [28] Siddaiah R, Saini RP. A review on planning, configurations, modeling and optimization techniques of hybrid renewable energy systems for off grid applications. *Renewable Sustainable Energy Rev* 2016;58:376–96.
- [29] Rao RV. Jaya: a simple and new optimization algorithm for solving constrained and unconstrained optimization problems. *Int J Ind Eng Comput* 2016;7(1):19–34.
- [30] Rao RV, Savsani VJ, Vakharia DP. Teaching-learning-based optimization: a novel method for constrained mechanical design optimization problems. *Comput Aided Des* 2011;43(3):303–15.
- [31] Rao RV, Patel V. An improved teaching-learning-based optimization algorithm for solving unconstrained optimization problems. *Sci Iran* 2013;20(3):710–20.
- [32] Khan A, Javaid N, Javaid S. Optimum unit sizing of stand-alone PV–WT–battery hybrid system components using Jaya. In: Proceedings of the 2018 IEEE 21st International Multi Topic Conference; 2018 Nov 1–2; Karachi, Pakistan. p. 1–8.
- [33] Mohammadi M, Hosseini SH, Gharehpetian GB. Optimization of hybrid solar energy sources/wind turbine systems integrated to utility grids as microgrid

- (MG) under pool/bilateral/hybrid electricity market using PSO. *Sol Energy* 2012;86(1):112–25.
- [34] Kellogg WD, Nehrir MH, Venkataramanan G, Gerez V. Generation unit sizing and cost analysis for stand-alone wind, photovoltaic, and hybrid wind/PV systems. *IEEE Trans Energy Convers* 1998;13(1):70–5.
- [35] Khan A, Javaid N, Khan MI. Time and device based priority induced comfort management in smart home within the consumer budget limitation. *Sustain Cities Soc* 2018;41:538–55.
- [36] Yousafzai AA, Khan A, Javaid N, Hussain HM, Abdul W, Almogren A, et al. An optimized home energy management system with integrated renewable energy and storage resources. *Energies* 2017;10(4):549.
- [37] Khan A, Javaid N, Ahmad A, Akbar M, Khan ZA, Ilahi M. A priority-induced demand side management system to mitigate rebound peaks using multiple knapsack. *J Ambient Intell Humanized Comput* 2019;10(4):1655–78.
- [38] Yang H, Zhou W, Lu L, Fang Z. Optimal sizing method for stand-alone hybrid solar–wind system with LPSP technology by using genetic algorithm. *Sol Energy* 2008;82(4):354–67.
- [39] Statistics on renewable met mast stations (SATBA): Kerman [Internet]. Tehran: Renewable Energy and Energy Efficiency Organization; [cited 2018 Apr 2]. Available from: <http://www.satba.gov.ir/en/regions/kerman>.



Nadeem Javaid received the bachelor degree in computer science from Gomal University, Dera Ismail Khan, Pakistan, in 1995, the master degree in electronics from Quaid-i-Azam University, Islamabad, Pakistan, in 1999, and the Ph.D. degree from the University of Paris-Est, France, in 2010. He is currently an Associate Professor and the Founding Director of the Communications Over Sensors (ComSens) Research Laboratory, Department of Computer Science, COMSATS University Islamabad, Islamabad. He has supervised 120 master and 16 Ph.D. theses. He has authored over 900 articles in technical journals and international conferences. His research interests include energy optimization in smart/micro grids, wireless sensor networks, big data analytics in smart grids, and blockchain in WSNs, smart grids, etc. He was recipient of the Best University Teacher Award from the Higher Education Commission of Pakistan, in 2016, and the Research Productivity Award from the Pakistan Council for Science and Technology, in 2017. He is also Associate Editor of *IEEE Access*, Editor of the *International Journal of Space-Based and Situated Computing* and editor of *Sustainable Cities and Society*.



Asif Khan received his MS degree in Computer Science from the BUITEMS University, Quetta, in 2015 and the Ph.D. degree in Computer Science in 2019 from the Communications Over Sensors (ComSens) Research Laboratory, Department of Computer Science, under the supervision of Dr. Nadeem Javaid from COMSATS University Islamabad, Islamabad Pakistan. His research interests include: energy optimization in micro and smart grids.